



# CITY OF RICHMOND

Department of Public Utilities

400 Jefferson Davis Highway, Richmond, VA 23224

Date: 10/24/2018

## **DANGER - NOTICE OF HAZARDOUS CONDITION**

RRHA

2341 Carmine St. #D37

Richmond, VA 23223

Utility Account Number: 250552-0014105

Location of Tag: Range

On 10/11/2018, the Department of Public Utilities' ("DPU") service technician placed a red warning tag on at your home (please refer to the enclosed copy of the red tag). Until the conditions recorded on the red tag are corrected by a qualified person the affected appliance or piping cannot be turned on. It is your responsibility to contact a licensed contractor to make needed repairs.

Please be advised that permits and inspections are required for the replacement of any gas-fired appliance, gas piping or gas exhaust vent prior to placing the appliance, piping or exhaust vent into service. Please contact your local building inspections department at the telephone number noted below regarding the permit and inspections processes.

Thank you for cooperating with this request.

CITY OF RICHMOND DEPARTMENT OF PUBLIC UTILITIES

cc: Local Building Department

**Local Building Department Contact Information:**

City of Richmond – Department of Community Development – (804) 646-6955

Chesterfield County – Department of Building Inspections – (804) 751-4990

Henrico County – Department of Building Construction and Inspections – (804) 501-4360

Address  
City

2341 Carmine St  
Richmond VA

6588  
Apt. D37

# WARNING

NOT SAFE TO OPERATE!

RISK OF INJURY TO PERSON OR PROPERTY!

This appliance or section of gas line has been shut off  
DO NOT use it until the conditions noted below have been corrected

Type of Service: ☐ Commercial ☒ Residential

Gas turned off at: A Valve

☒ Range ☐ Meter ☐ Appliance Shut Off Valve  
☐ Gaslight ☐ Furnace ☐ Water Heater  
☐ Pool Heater ☐ Dryer ☐ Gas Logs  
☐ Generator ☐ Other

## Conditions Found

☐ Gas Pipe Leaking ☐ Vent Pipe Obstructed  
☐ Improper Venting ☐ Spillage  
☒ Defective Control Valve ☐ No Pilot Safety  
☐ Cracked Heat Exchanger ☒ Gas Leak at Appliance  
☒ Appliance Needs Cleaning Connection  
☐ Unvented ☐ No Relief Valve  
☐ Carbon Monoxide PPM: \_\_\_\_\_ ☐ Improper Ignition  
☐ Vent Pipe Deteriorated ☐ Over Firing  
☐ Failed Pilot Safety ☐ Other

Remarks: Pick up 2 1/2 gal of  
Right front burner. T/OFF at valve  
made leak safe. Appliance needs cleaning

I have been notified of the unsafe conditions indicated by the items above. I understand that it is my responsibility to arrange for the necessary repairs immediately. FAILURE TO DO SO MAY RESULT IN PROPERTY DAMAGE, SERIOUS BODILY INJURY OR DEATH. I further understand that a plumber, contractor or qualified person must make repairs and that the affected appliance or piping must not be used under any circumstances until repairs have been made.

Customer Signature: \_\_\_\_\_

Owner \_\_\_\_\_ Tenant ☒ Other \_\_\_\_\_

Customer Telephone Number \_\_\_\_\_

Employee: \_\_\_\_\_

Date: 10/11/18

No one here to sign ( ) \* Consumer refused to sign ( ) \* Requires a follow up letter to be sent

## It's Up to You!

You are responsible for the safe operation of your gas appliances, including the correction and repairs of the conditions checked on this warning card and for injury or damage resulting from any unsafe conditions. City of Richmond Department of Public Utilities has reported the unsafe conditions indicated on this warning card to the Building Inspections agency in the appropriate jurisdiction. When repairs have been completed the contractor or person(s) that have made the repairs will be responsible for relighting the pilots, etc.

If you have any questions  
please call  
City of Richmond  
Department of Public Utilities  
(804) 644-3000



CITY OF RICHMOND  
DEPARTMENT OF PUBLIC UTILITIES

